



# OPT2145-OPT2158

**Reflex Sensors with Background Suppression** 



**Operating Instructions** 

### **Table of Contents**

1.	General	3
	1.1 Information Concerning these Instructions	3
	1.2 Explanations of Symbols	3
	1.3 Limitation of Liability	4
	1.4 Copyrights	4
2.	For Your Safety	5
	2.1 Use for Intended Purpose	
	2.2 Use for Other than the Intended Purpose	
	2.3 Personnel Qualifications	6
	2.4 Modification of Products	6
	2.5 General Safety Precautions	
	2.6 Laser/LED Warnings	
	2.7 Approvals and protection class	6
3.	Technical Data	7
	3.1 Spot Diameter	8
	3.2 Switching Distance Deviation	
	3.3 Layout	
	3.4 Control Panel	
	3.5 Scope of Delivery	10
4.	Transport and Storage	11
	4.1 Transport	
	4.2 Storage	11
5.	Installation and Electrical Connection	11
	5.1 Installation	11
	5.2 Electrical Connection	12
	5.3 Diagnostics	13
6.	Settings	14
	6.1 Object Detection Directly in Front of a Background or an Undersurface	
	6.2 Detection of Objects Without Interfering Background	14
7.	IO-Link	14
8.	Maintenance Instructions	15
•		_
9.	Proper Disposal	
10.	Appendix	
	10.1 List of Abbreviations	_
	10.2 Change Index, Operating Instructions	
	10.2 ELL Doctoration of Conformity	15



### 1. General

### 1.1 Information Concerning these Instructions

- These instructions apply to the products with ID code OPT21xx.
- They make it possible to use the product safely and efficiently.
- These instructions are an integral part of the product and must be kept on hand for the entire duration of its service life.
- · Local accident prevention regulations and national work safety regulations must be complied with as well.
- The product is subject to further technical development, and thus the information contained in these operating instructions may also be subject to change. The current version can be found at www.automationdirect.com in the product's separate download area.



#### NOTE!

The operating instructions must be read carefully before using the product and must be kept on hand for later reference.

### 1.2 Explanations of Symbols

- · Safety precautions and warnings are emphasized by means of symbols and attention-getting words
- Safe use of the product is only possible if these safety precautions and warnings are adhered to

The safety precautions and warnings are laid out in accordance with the following principle:



## Attention-Getting Word! Type and Source of Danger!

Possible consequences in the event that the hazard is disregarded.

· Measures for averting the hazard.

The meanings of the attention-getting words, as well as the scope of the associated hazards, are listed below.



#### DANGER!

This word indicates a hazard with a high degree of risk which, if not avoided, results in death or severe injury.



#### WARNING!

This word indicates a hazard with a medium degree of risk which, if not avoided, may result in death or severe injury.



#### CAUTION!

This word indicates a hazard with a low degree of risk which, if not avoided, may result in minor or moderate injury.



#### ATTENTION!

This word draws attention to a potentially hazardous situation which, if not avoided, may result in property damage.



### NOTE!

A note draws attention to useful tips and suggestions, as well as information regarding efficient, error-free use.

### 1.3 Limitation of Liability

- The product has been developed in consideration of the current state-of-the-art and applicable standards and guidelines. Subject to change without notice.
- A valid declaration of conformity can be accessed at www.automationdirect.com in the product's separate download area.
- wenglor sensoric elektronische Geräte GmbH (hereinafter referred to as "wenglor") excludes all liability in the event of:
  - · Non-compliance with the instructions
  - Use of the product for purposes other than those intended
  - · Use by untrained personnel
  - · Use of unapproved replacement parts
  - Unapproved modification of products
- These operating instructions do not include any guarantees from wenglor with regard to the described procedures or specific product characteristics.
- wenglor assumes no liability for printing errors or other inaccuracies contained in these operating
  instructions, unless wenglor was verifiably aware of such errors at the point in time at which the operating
  instructions were prepared.

### 1.4 Copyrights

- The contents of these instructions are protected by copyright law.
- · All rights are reserved by wenglor.
- Commercial reproduction or any other commercial use of the provided content and information, in particular graphics and images, is not permitted without previous written consent from wenglor.

4 General



### 2. For Your Safety

### 2.1 Use for Intended Purpose

The product is based on the following functional principle:

#### Reflex Sensors with Background Suppression

Reflex sensors with background suppression analyze the light reflected from objects. As these sensors work according to the principle of angular measurement, the color, shape and surface characteristics of the object have almost no influence on the detection range. Even dark objects can be reliably detected against a bright background. The output is switched as soon as an object passes the selected range.

### This product can be used in the following industry sectors:

- Special machinery manufacturing
   Consumer goods industry
- Heavy machinery manufacturing
- Paper industry

Logistics

- · Electronics industry
- · Automotive industry
- Glass industry

Food industry

- Steel industry
- · Packaging industry
- Aviation industry
- Pharmaceuticals industry
- · Chemicals industry

· Plastics industry

- Alternative energy
- Woodworking industry
- · Raw materials extraction

### 2.2 Use for Other than the Intended Purpose

- Not a safety component in accordance with 2006/42/EC (Machinery Directive)
- The product is not suitable for use in potentially explosive atmospheres.
- The product may only be used with accessories supplied or approved by wenglor, or combined with approved products. A list of approved accessories and combination products can be accessed at www.wenglor.com on the product detail page.

#### DANGER!



Risk of personal injury or property damage in case of use for other than the intended purpose!

Use for other than the intended purpose may lead to hazardous situations.

Observe instructions regarding use for intended purpose.

### 2.3 Personnel Qualifications

- Suitable technical training is a prerequisite.
- In-house electronics training is required.
- Trained personnel must have uninterrupted access to the operating instructions.



#### DANGER!

## Risk of personal injury or property damage in case of incorrect initial start-up and maintenance!

Personal injury and damage to equipment may occur.

Adequate training and qualification of personnel.

### 2.4 Modification of Products

#### DANGER!

### Risk of personal injury or property damage if the product is modified!



Personal injury and damage to equipment may occur. Non-observance may result in loss of the CE marking and the guarantee may be rendered null and void.

Modification of the product is impermissible.

### 2.5 General Safety Precautions

#### NOTE!

These instructions are an integral part of the product and must be kept on hand for the
entire duration of its service life.



- In the event of possible changes, the respectively current version of the operating instructions can be accessed at www.automationdirect.com in the product's download area
- Read the operating instructions carefully before using the product.
- Protect the sensor against contamination and mechanical influences.

### 2.6 Laser/LED Warnings

The respective laser class or LED group is listed in the product's technical data.



Laser Class 1 (EN 60825-1)

Applicable standards and safety regulations must be observed. Pp = 7 mW, t = 8 s,  $\lambda$  = 680 nm

### 2.7 Approvals and protection class









6 For Your Safety



### 3. Technical Data

Optical Data				
100000 h				
10000 Lux				
1530 V DC				
1830 V DC				
−4060 °C				
< 2 V				
100 mA				
< 50 µA				
Yes				
IO-Link				
1.1				
III				
Potentiometer				
Plastic				
IP67/IP68				
PMMA				

Order Number		OPT							
Technical Data		2147	2148	2157	2158	2149	2150	2153	2154
Principle		Electronic background suppression							
Range		200	mm	300 mm		500 mm		1200 mm	
Adjustable F	Range	502	00 mm	50300 mm		60500 mm		1001200 mm	
Switching h	ysteresis	< ;	5 %			< !	5 %	< ;	5 %
Temperature	e drift	< !	5 %			< !	5 %	< (	6 %
Current con	sumption	< 20	) mA			< 20	) mA	< 20 mA	
Light Source	е	Red	light	La	ser	Red light		Red light	
Laser Class	(EN 60825-1)	-	_		l	-	_	-	_
Spot Diameter		see Table 1				see T	able 2	see T	able 3
Switching frequency		800 Hz		800	Hz	800	Hz	600	Hz
Response time		1,25	1,25 ms 1,25		ms	1,25	ms	1,5	ms
Switching frequency (Interference-free-Mode)		500	) Hz	500	Hz	500	) Hz	400	Hz
Response time (Interference-free-Mode)		21	ms	2 1	ms	2 1	ms	2 :	ms
Output	PNP, antivalent	×		×		×		×	
function	NPN, antivalent		×		×		×		×
Connection		Plug M1	2, 4-pin	Plug M1	2, 4-pin	Plug M1	2, 4-pin	Plug M1	2, 4-pin
Connection	diagram No.	215	213	215	213	213	215	215	213

### 3.1 Spot Diameter

Range	50 mm	100 mm	200 mm
Spot diameter	7 mm	7 mm	5 mm

Table 1

Range	60 mm	250 mm	500 mm
Spot diameter	11 mm	13 mm	15 mm

Table 2


Range	100 mm	600 mm	1200 mm
Spot diameter	14 mm	17 mm	24 mm

Table 3

### 3.2 Switching Distance Deviation

Typical characteristic curve based on Kodak white (90 % remission).

### OPT2153, OPT2154:




Sr = Switching Distance dSr = Switching Distance Change Black 6 % remission Grey 18 % remission

8 Technical Data




### 3.3 Layout

### OPT2147, OPT2148, OPT2149, OPT2150, OPT2157, OPT2158




### OPT2153, OPT2154



① = Emitter diode ② = Receiving diode Screw M4 = 0,5 Nm Potentiometer = 40 Nmm Dimensions specified in mm (1 mm = 0,03937 Inch)

### 3.4 Control Panel



05 = switching distance adjuster 30 = switching status indicator / contamination warning

68 = supply power indicator

### 3.5 Scope of Delivery

- Sensor
- · Safety precautions
- BEF-SET-14
- Spacer sleeves Z1PE002

10 Technical Data



### 4. Transport and Storage

### 4.1 Transport

Upon receipt of shipment, the goods must be inspected for damage in transit. In the case of damage, conditionally accept the package and notify the manufacturer of the damage. Then return the device, making reference to damage in transit.

### 4.2 Storage

#### The following points must be taken into condition with regard to storage:

- Do not store the product outdoors.
- Store the product in a dry, dust-free place.
- · Protect the product against mechanical impacts.
- Protect the product against exposure to direct sunlight.

#### ATTENTION!



#### Risk of property damage in case of improper storage!

The product may be damaged.

• Storage instructions must be complied with.

### 5. Installation and Electrical Connection

#### 5.1 Installation

- Protect the product from contamination during installation.
- · Observe all applicable electrical and mechanical regulations, standards, and safety rules.
- Protect the product against mechanical influences.
- · Make sure that the sensor is mounted in a mechanically secure fashion.
- Specified torque values must be complied with (see section "3. Technical Data", page 7).

#### ATTENTION!



#### Risk of property damage in case of improper installation!

The product may be damaged.

Installation instructions must be complied with.

### **CAUTION!**




### Risk of personal injury or property damage during installation!

Personal injury and damage to the product may occur.

· A safe installation environment must be assured.

#### 5.2 Electrical Connection



#### Legend Supply Voltage + Supply Voltage 0 V Supply Voltage (AC Voltage) (NO) Switching Output Α Switching Output (NC) Contamination/Error Output (NO) Contamination/Error Output Е Input (analog or digital) Т Teach Input Z Time Delay (activation) S Shielding RxD Interface Receive Path Interface Send Path TxD RDY Ready GND Ground Clock CL Output/Input programmable E/A IO-Link Power over Ethernet PoE Safety Input OSSD Safety Output Signal Output BI\_D+/- Ethernet Gigabit bidirect. data line (A-D) ENORS422 Encoder 0-pulse 0-0 (TTL)

PT	Platinum measuring resistor
nc	not connected
U	Test Input
Ū	Test Input inverted
W	Trigger Input
W -	Ground for the Trigger Input
0	Analog Output
0-	Ground for the Analog Output
BZ	Block Discharge
Awv	Valve Output
а	Valve Control Output +
b	Valve Control Output 0 V
SY	Synchronization
SY-	Ground for the Synchronization
E+	Receiver-Line
S+	Emitter-Line
<b>±</b>	Grounding
SnR	Switching Distance Reduction
Rx+/-	Ethernet Receive Path
Tx+/-	Ethernet Send Path
Bus	Interfaces-Bus A(+)/B(-)
La	Emitted Light disengageable
Mag	Magnet activation
RES	Input confirmation
EDM	Contactor Monitoring

ENARS422	Encoder A/Ā (TTL)
ENBRS422	
ENA	Encoder A
ENB	Encoder B
Амін	Digital output MIN
Амах	Digital output MAX
Аок	Digital output OK
SY In	Synchronization In
SY OUT	Synchronization OUT
Оцт	Brightness output
М	Maintenance
rsv	reserved
Wire Co	olors according to IEC 60757
BK	Black
BN	Brown
RD	Red
OG	Orange
YE	Yellow
GN	Green
BU	Blue
VT	Violet
GY	Grey
WH	White
PK	Pink
GNYE Green/Yellow	



#### DANGER!

### Risk of personal injury or property damage due to electric current!

Voltage conducting parts may cause personal injury or damage to equipment.

• The electric device may only be connected by appropriately qualified personnel.




### 5.3 Diagnostics

Causes for Triggering the Contamination Warning (blinking LED):

Display LED	Diagnosis/Cause	Elimination
	Contamination	Carefully clean the optic cover with a cloth.
Continuous blinking	Aged emitter diode	Replace the sensor.
at approx. 2.5 Hz	Unreliable working range	Increase the sensor's switching distance.     Reduce distance between sensor and object.
	Short-circuit	Check electrical wiring and eliminate the short-circuit.
Continuous blinking at approx. 5 Hz	Over-temperature	Disconnect the sensor from supply power and allow it to cool down.
	Hardware error	Replace the sensor.

### **Contamination Warning Flowcharts**



#### Required action in case of fault:

#### NOTE!

- · Shut down the machine.
- Analyze and eliminate the cause of error with the help of the diagnostics information.
- If the error cannot be eliminated, please contact AutomationDirect's support department.
- Do not operate in case of indeterminate malfunctioning.
- The machine must be shut down if the error cannot be unequivocally clarified or reliably eliminated





### Risk of personal injury or property damage in case of non-compliance!

The system's safety function is disabled. Personal injury and damage to equipment.

· Required action as specified in case of fault.

### 6. Settings

### 6.1 Object Detection Directly in Front of a Background or an Undersurface

- Adjust and securely mount the sensor such that the spot strikes the object to be detected at a right angle.
- Turn the potentiometer all the way to the right.
- Remove the object and slowly turn the potentiometer back until the output is switched. The background or the undersurface is now suppressed.
- Put the object back under the spot and check to determine whether or not the sensor is activated again.

### 6.2 Detection of Objects Without Interfering Background

- Adjust and securely mount the sensor such that the spot strikes the object to be detected.
- Turn the potentiometer all the way to the left.
- Turn up the potentiometer up until activation occurs and, if required, turn it up a bit further for increased switching reliability.

### 7. IO-Link

Further settings are possible via the IO-Link interface. The IODD can be found at www.automationdirect.com in the product's download area.

14 Settings



### 8. Maintenance Instructions

#### NOTE!



- This wenglor sensor is maintenance-free.
- Cleaning and inspection of the plug connections at regular intervals are advisable.
- Do not clean the sensor with solvents or cleansers which could damage the product.
- The product must be protected against contamination during initial start-up.

### 9. Proper Disposal

wenglor sensoric GmbH does not accept the return of unusable or irreparable products. Respectively valid national waste disposal regulations apply to product disposal.

### 10. Appendix

### 10.1 List of Abbreviations

Abbreviation	Meaning
Tu Ambient temperature	
Ub	Supply voltage
IODD	IO Device Description
MTTFd	Mean Time to Dangerous Failure

### 10.2 Change Index, Operating Instructions

Version	Date	Description/Change		
1.0.0	19.09.19	Initial version of the operating instructions		

### 10.3 EU Declaration of Conformity

The EU declaration of conformity can be found on our website at www.automationdirect.com in the product's download area.