



Wiring System for CLICK PLCs

Cut your PLC wiring time down to minutes instead of hours

The ZIPLink wiring system eliminates the normally tedious process of wiring PLC I/O to terminal blocks. Simply plug one end of a ZIPLink pre-wired terminal block cable into your CLICK module and the other end into a ZIPLink connector module. It's that easy. ZIPLinks use half the space, at a fraction of the total cost of terminal blocks.

ZIPLinks are available in a variety of styles to suit your needs, including feedthrough connector module. ZIPLinks are available for all basic CLICK CPU modules and all discrete input and output modules.



Specify your ZIPLink system

Use the Compatibility Matrix table below:



NOTE: ZIPLINKS ARE ONLY AVAILABLE FOR BASIC CPU MODULES; THEY ARE NOT AVAILABLE FOR ANALOG CPU MODULES.

Step 1	Locate the CLICK CPU module or I/O module part number.
Step 2	Locate compatible connector module type.
Step 3	Select the cable length by replacing the # symbol with: Blank = 0.5m, -1 = 1.0m, -2 = 2.0m

ZIPLink Wiring System Compatibility Matrix for CLICK PLCs						
	Step 2: Connector Module Type		Feedthrough Module	Fuse Module	Relay Modules	Sensor Input Module
	Step 1: I/O unit	Number of Terminals	ZL-RTB20	ZL-RFU20	ZL-RRL16-24	ZL-LTB16-24
CPU Module	Step 3: Cables					
	CO-00DD1-D	20	ZL-CO-CBL20#			
	CO-00DD2-D	20	ZL-CO-CBL20#			
	CO-00DR-D	20	ZL-CO-CBL20#			
CO-00AR-D	20	ZL-CO-CBL20#				
I/O Module	Inputs					
	CO-08ND3	11	ZL-CO-CBL11#			
	CO-08ND3-1	11	ZL-CO-CBL11#			
	CO-08NA	11	ZL-CO-CBL11#			
	CO-16ND3	20	ZL-CO-CBL20#			ZL-CO-CBL20#
	Outputs					
	CO-08TD1	11	ZL-CO-CBL11#			
	CO-08TD2	11	ZL-CO-CBL11#			
	CO-08TR	11	ZL-CO-CBL11#			
	CO-08TA	11	ZL-CO-CBL11#			
	CO-16TD1	20	ZL-CO-CBL20#	ZL-CO-CBL20#	ZL-CO-CBL20#	
	CO-16TD2	20	ZL-CO-CBL20#	ZL-CO-CBL20#		
CO-04TRS*	20	ZL-CO-CBL20#				

*Note: The CO-04TRS relay output is derated not to exceed 2 Amps per point max. when used with the ZIPLink wiring system

ZIPLink Connector Modules specifications begin on page 26-56

ZIPLink Cables specifications begin on page 26-74